

PLANTA POTABILIZADORA PASTOR LOZANO


ANÁLISIS FÍSICOQUÍMICOS  
AGUA CRUDA RÍO BRAVO  
MAYO 2022

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	PROMEDIO
TURBEDAD N.T.U.	31.6	30.1	18.3	24.3	24.6	22.0	33.3	29.7	34.2	35.7	26.6	28.7	29.8	29.1	25.3	31.5	31.0	296.0	108.0	70.8	31.8	25.7	40
P.H.	7.4	7.5	7.6	7.5	7.4	7.4	7.4	7.5	7.4	7.4	7.3	7.5	7.2	7.4	7.5	7.6	7.1	6.8	7.0	7.2	7.3	7.3	7.3
ALCALINIDAD TOTAL	120	118	128	116	130	152	142	128	122	136	122	112	122	110	134	130	84	120	110	102	114	106	121
DUREZA TOTAL	332	384	406	394	362	356	358	322	324	334	300	342	334	330	300	328	238	302	306	340	320	356	334
DUREZA DE CALCIO	226	192	236	206	140	160	188	174	180	142	160	216	164	152	146	204	158	158	186	180	166	180	178
D. DE MAGNESIO	106	192	170	188	212	196	170	148	144	192	140	128	170	178	154	124	80	144	120	180	154	176	157
CLORUROS	213	280	315	280	232	228	227	210	192	187	190	182	180	170	160	165	120	150	178	197	206	210	204
SDT	724	801	828	778	735	810	712	870	648	618	657	716	677	832	948	705	422	552	612	702	652	681	713
TEMPERATURA °C	26.2	26.8	27.1	27.0	27.7	29.0	28.8	27.9	27.3	27.2	22.4	17.9	27.6	27.2	27.3	28.6	26.3	25.6	27.3	28.1	30.0	30.0	27

AUTORIZÓ:

  
I.C. EDNA MARISSA SOTO LOZANO  
ENCARGADA DE LABORATORIO

  
BIÓLOGO GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA