

PLANTA POTABILIZADORA PASTOR LOZANO


ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA CANAL RODHE
MAYO 2022

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	PROMEDIO
TURBIEDAD N.T.U.	35.9	29.5	32.2	37.4	34.6	26.2	44.5	46.4	37.9	29.4	27.3	27.7	32.2	22.4	26.8	23.9	27.5	57.8	44.8	29.7	31.1	32.0	34
P.H.	7.8	7.7	7.8	7.8	7.8	7.6	7.7	7.8	7.9	7.7	7.5	7.7	7.4	7.5	7.7	7.8	7.2	7.1	7.0	7.1	7.2	7.2	7.5
ALCALINIDAD TOTAL	110	114	106	106	126	130	120	124	118	130	124	120	108	106	126	134	70	136	118	112	106	104	116
DUREZA TOTAL	386	434	432	420	406	420	386	400	390	400	376	360	380	372	398	360	280	400	356	346	360	346	362
DUREZA DE CALCIO	176	194	180	190	194	148	206	182	206	194	186	250	186	178	252	206	170	192	214	214	178	168	194
D. DE MAGNESIO	210	240	252	230	212	272	178	218	184	206	192	130	194	194	146	152	82	208	142	132	182	180	188
CLORUROS	245	250	250	258	246	243	250	265	252	263	241	240	250	240	235	200	133	225	222	215	226	328	239
SDT	781	774	780	755	749	756	736	727	746	739	795	876	832	1014	1169	815	454	749	714	642	697	706	772
TEMPERATURA °C	26.7	27.1	27.3	26.9	27.7	29.2	26.4	26.1	27.5	27.1	26.0	26.1	27.9	27.4	27.7	26.5	26.1	26.0	27.1	26.2	29.8	30.0	26

AUTORIZÓ:


I.Q. EDNA MARISSA SOTO LOZANO
ENCARGADA DE LABORATORIO

Yo, Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA