

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
JUNIO 2022

RÉSULTADOS EN MG/LT

FECHA:	1	2	3	6	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	4.7	4.5	4.1	4.0	5.0	4.9	5.0	5.0	5.0	4.8	5.0	4.0	4.5	4.8	5.0	4.4	4.7	5.0	4.9	4.7	5.0	5 NTU	4.7
P.H.	7.0	7.1	7.0	7.1	7.2	7.4	7.1	7.2	7.3	7.0	7.1	7.0	7.2	7.3	7.2	7.3	7.2	7.2	7.1	7.7	6.8	7.0	6.5-8.5	7.2
ALCALINIDAD TOTAL	112	114	120	102	108	116	119	127	138	123	106	104	109	110	106	94	94	108	114	112	100	106		111
DUREZA TOTAL	340	346	340	350	344	328	320	316	317	310	311	317	320	328	310	310	312	322	284	284	288	316	500 MG/LT	319
DUREZA DE CALCIO	182	196	185	196	182	178	169	174	168	174	156	164	156	150	164	170	176	180	144	160	138	170		170
D. DE MAGNESIO	148	150	155	154	162	152	151	142	149	136	155	153	164	178	146	140	136	142	140	124	150	146		149
CLORUROS	210	209	200	197	214	222	210	217	207	199	201	178	199	184	172	176	182	165	143	152	146	156	250 MG/LT	188
CLORO RESIDUAL	1.5	1.5	1.4	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.4	1.5	1.3	1.5	1.5	1.3	1.4	1.5	1.5	1.5	1.5	1.5	0.2-1.5	1.5
SDT	734	780	760	776	790	741	798	785	737	766	793	643	633	617	600	680	713	690	720	585	605	607	1000 MG/LT	704
TEMPERATURA °C	30.9	30.5	30.6	30.8	29.8	30.4	30.3	30.6	30.5	30.1	29.6	29.7	30.1	30.4	30.5	30.7	30.6	29.8	30.3	30.9	30.5	30.9		31

AUTORIZÓ:

Vo.Bo.


I.Q. TERESITA BERENICE LOPEZ MELGAR
ENCARGADA DE LABORATORIO


BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA