

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS  
AGUA CRUDA CANAL RODHE  
JUNIO 2022

RESULTADOS EN MG/LT

FECHA:	1	2	3	6	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	29	30	PROMEDIO
TURBIEDAD N.T.U.	25.4	29.7	27.8	28.0	31.2	38.7	48.2	60.3	38.9	29.8	20.5	36.8	30.9	30.1	27.2	20.9	26.5	32.2	41.0	36.7	44.2	40.6	34
P.H.	7.2	7.3	7.3	7.0	7.4	7.9	7.9	7.9	7.8	8.0	7.9	7.4	7.8	7.5	7.1	7.6	7.4	7.5	7.5	7.8	7.5	7.4	7.5
ALCALINIDAD TOTAL	116	118	122	122	111	119	114	112	116	118	110	132	128	124	110	100	104	120	112	102	102	100	114
DUREZA TOTAL	370	380	348	340	336	348	347	384	396	388	396	392	380	400	410	400	418	398	378	390	390	394	381
DUREZA DE CALCIO	212	226	208	206	200	203	212	242	233	221	226	218	210	222	223	227	244	219	201	216	222	217	219
D. DE MAGNESIO	158	154	140	134	136	145	135	142	163	167	170	174	170	178	187	173	174	179	177	174	168	177	163
CLORUROS	250	285	275	250	258	247	229	217	210	221	273	270	268	250	249	267	278	264	240	266	255	260	254
SDT	718	785	784	797	802	796	804	793	798	715	820	806	750	710	680	720	775	713	788	725	737	797	764
TEMPERATURA °C	30.3	30.4	30.6	29.8	29.7	29.7	30.1	30.4	29.1	30.1	28.6	28.7	28.4	30.2	30.0	30.2	30.3	30.1	29.9	30.6	31.0	30.2	30

AUTORIZÓ:



I.Q. TERESITA BERENICE LOPEZ MELGAR  
ENCARGADA DE LABORATORIO

Ve-Bo



BIOLOGO GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA