

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA POTABLE
 JULIO 2022

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	16	19	20	21	22	25	26	27	29	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	4.7	4.9	5.0	5.0	5.0	4.5	5.0	4.8	4.8	5.0	4.2	3.1	4.8	4.0	4.9	3.9	4.3	4.3	4.9	5 NTU	4.6
P.H.	7.2	7.2	7.3	7.2	7.0	7.1	7.0	7.1	7.2	7.0	7.2	7.3	7.0	7.4	7.5	7.0	7.1	7.0	7.0	7.1	6.5-8.5	7.1
ALCALINIDAD TOTAL	101	102	100	98	104	108	112	108	100	102	101	112	118	102	114	119	120	112	106	104		107
DUREZA TOTAL	300	301	296	290	294	298	286	299	302	298	304	280	284	280	276	286	287	277	270	268	500 MG/LT	288
DUREZA DE CALCIO D. DE	180	178	170	160	170	180	166	178	180	170	177	170	169	176	172	160	177	165	158	150		170
MAGNESIO	120	123	126	130	124	118	120	121	122	128	127	110	115	104	104	106	110	112	112	118		118
CLORUROS	160	161	163	164	149	150	165	162	160	174	170	165	158	143	136	145	160	155	155	146	250 MG/LT	157
CLORO RESIDUAL	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.0	1.1	1.5	1.5	0.2-1.5	1.5
SOT	598	535	565	554	498	574	502	567	590	563	562	577	602	505	575	596	595	588	596	580	1000 MG/LT	571
TEMPERATURA °C	31.0	30.8	26.5	24.4	25.2	24.3	28.0	24.1	23.6	24.8	25.6	28.4	22.4	22.3	23.2	25.1	25.5	26.6	26.6	24.6		25.7

AUTORIZÓ:

Vc. Bo.


 IQ. TERESITA BERENICE LOPEZ MELGAR
 ENCARGADA DE LABORATORIO


 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA