

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS  
 AGUA CRUDA RIO BRAVO  
 AGOSTO 2022

RESULTADOS EN MG/LT

FECHA	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	PROMEDIO
TURBIDEZ N.T.U.	20.1	20.5	25.5	25.4	26.2	21.2	20.7	22.0	15.7	17.1	16.4	18.4	16.5	14.8	15.5	14.0	16.5	19.8	18.3	15.2	20.3	19.6	17.9	19.0
P.H.	7.7	7.6	7.6	7.7	7.1	7.1	7.2	7.2	7.5	7.3	7.0	7.0	7.1	7.0	7.3	7.2	7.0	7.2	7.1	7.1	7.6	7.4	7.7	7.3
ALCALINIDAD TOTAL	102	114	110	106	100	106	118	116	120	118	116	120	118	110	108	111	115	119	126	108	124	116	109	114
DUREZA TOTAL	280	290	280	302	306	322	333	314	308	294	292	299	301	306	300	296	302	280	292	296	293	302	340	301
DUREZA DE CALCIO	164	168	170	178	180	188	194	180	186	170	160	158	162	165	166	160	154	140	155	150	148	162	199	168
DUREZA DE MAGNESIO	116	122	110	124	126	134	139	134	122	124	132	141	139	141	134	136	148	140	137	146	145	140	141	134
CLORUROS	144	147	146	149	146	158	155	159	162	145	134	146	144	148	145	144	150	165	172	170	176	188	196	156
SDI	527	596	608	680	646	686	580	500	513	500	509	505	550	575	600	585	608	690	699	590	586	599	650	591
TEMPERATURA °C	24.7	24.9	26.9	27.8	27.3	25.8	26.5	28.0	27.4	27.7	26.1	26.6	27.4	25.7	29.2	26.5	25.2	25.6	23.0	27.5	26.4	22.7	23.3	26.2

AUTORIZO:

Vo-Bo.

*[Signature]*

I.Q. TERESITA BERENICE LOPEZ MELGAR  
 JEFE DE LABORATORIO

BIOLOGO GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA