

PLANTA POTABILIZADORA PASTOR LOZANO
ANALISIS FISICOQUÍMICOS
AGUA POTABLE
 may-17


RESULTADOS EN MG/LT

FECHA:	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	4.8	5.0	5.0	5.0	5.0	5.0	4.8	4.9	5.0	5.0	4.3	3.9	3.9	3.6	5.0	5.0	4.9	5.0	5.0	5.0	4.6	5 NTU.	4.8
P.H.	7.6	7.4	7.3	7.4	7.6	7.1	7.6	7.2	7.4	7.8	7.4	7.4	7.4	7.6	7.4	7.3	7.4	7.4	7.5	7.4	7.2	7.5	6.5-8.5	7.4
ALCALINIDAD TOTAL	72	78	86	96	74	78	86	88	78	80	80	88	86	76	86	78	64	88	80	78	74	80		80.6
DUREZA TOTAL	306	290	310	304	320	336	320	296	298	310	324	336	346	330	328	340	318	320	300	320	334	290	500 MG/LT	317.1
CLORUROS	188	170	172	180	180	185	188	200	186	205	210	205	203	194	180	170	210	200	210	210	186	195	250 MG/LT	191.2
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.3	1.4	1.2	1	1	1	1	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5		1.4
CALCIO	160	130	160	166	166	180	190	180	190	198	180	200	210	210	150	164	180	190	190	190	198	180		182.8
MAGNESIO	146	160	130	118	154	156	130	116	108	112	144	136	136	120	178	156	138	130	110	130	136	110		134.3
SDT	545	546.5	540	503	565	577.5	565	563.5	558	563	570	571.5	575	553	548.5	566	567.5	570	563	542	581	554.5	1000 MG/LT	558.4

Realizó

QFB. MIRIAM CAVAZDS GARCIA
 JEFE DE LABORATORIO

Ver: BCP



JUAN GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA