



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA POTABLE
 NOVIEMBRE 2022

RESULTADOS EN MG/LT

ECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	22	23	24	25	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD (T.U.)	4.9	4.5	4.8	4.9	5.0	4.9	5.0	4.8	4.9	5.0	4.9	5.0	4.8	4.6	4.7	4.7	4.9	5.0	4.8	4.9	5.0	5 NTU	4.9
pH	6.8	6.9	7.0	7.4	7.3	7.1	7.0	6.9	6.9	7.2	6.8	7.0	6.9	6.8	7.4	7.2	7.1	6.9	7.0	7.1	7.2	6,5-8,5	7.0
ALCALINIDAD TOTAL	100	108	110	109	112	108	100	110	102	106	115	114	112	110	126	128	120	112	118	114	110		112
DUREZA TOTAL	328	334	340	320	326	334	320	314	320	332	340	330	320	308	344	314	310	318	314	318	315	500 MG/LT	324
DUREZA DE CALCIO	188	180	184	172	177	188	199	190	180	194	196	197	198	194	216	208	200	206	200	199	198		194
DUREZA DE MAGNESIO	140	154	156	148	149	146	121	124	140	138	144	133	122	114	128	106	110	112	114	119	117		130
CLORUROS	187	198	196	180	172	186	216	232	238	200	192	182	180	178	165	168	175	181	182	174	180	250 MG/LT	189
CLORO RESIDUAL	1.3	1.5	1.5	1.5	1.5	1.5	1.4	1.4	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.5	1.3	1.2	1.5	1.3	1.3	0.2-1.5	1.4
DT	504	590	556	540	508	500	583	525	506	533	528	545	570	550	590	600	597	604	599	587	590	1000 MG/LT	557
TEMPERATURA (C)	22.7	21.8	23.1	24.3	24.4	24.3	23.4	23.5	23.8	21.3	21.2	19.7	17.2	17.3	13.7	14.7	16.5	16.9	18.5	19.9	22.8		20.5

AUTORIZÓ:

IQ. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO

Vd.Bo.

BIOLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA