



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA RIO BRAVO
 NOVIEMBRE 2022

RESULTADOS EN MG/LT

ECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	22	23	24	25	28	29	30	PROMEDIO
URBIEDAD (T.U.)	19.8	18.7	18.6	18.5	18.6	17.2	17.5	16.1	15.2	14.8	15.0	15.6	16.9	17.5	16.7	14.8	13.2	11.9	11.0	10.1	10.5	15.6
PH	7.3	7.0	6.6	6.9	6.8	6.7	7.1	7.2	7.0	7.0	7.1	7.0	7.0	6.7	7.2	7.5	7.3	7.6	7.9	7.8	7.7	7.2
ALCALINIDAD TOTAL	104	100	110	118	107	109	106	122	114	128	126	120	118	114	142	148	140	136	130	138	132	122
DUREZA TOTAL	260	278	280	262	272	264	268	244	266	277	284	278	290	288	267	278	288	282	290	286	284	276
DUREZA DE CALCIO	155	160	154	150	156	150	156	136	162	168	172	170	179	169	158	165	176	172	173	174	170	163
DUREZA DE MAGNESIO	105	118	126	112	116	114	112	108	104	109	112	108	111	119	109	113	112	110	117	112	114	112
CLORUROS	115	132	145	136	132	140	148	150	156	162	160	150	156	153	150	136	138	140	142	138	140	144
ODI	402	426	413	445	466	400	440	488	402	502	510	514	510	490	609	556	524	511	500	503	512	482
TEMPERATURA (C)	22.1	21.7	23.0	23.9	24.0	24.1	23.6	23.7	23.5	20.7	17.3	21.2	16.7	17.3	13.3	14.3	14.6	16.2	17.8	19.8	21.4	20.0

AUTORIZÓ:

I.Q. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO

Vo.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA