



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA POTABLE
 DICIEMBRE 2022



RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	4.4	5.0	4.1	5.0	4.8	4.4	4.7	5.0	4.9	5.0	4.8	5.0	4.9	5.0	4.8	5.0	4.3	5.0	4.9	4.8	4.6	5 NTU	4.8
P.H.	7.1	7.0	7.2	7.4	7.3	7.3	7.0	7.0	7.5	7.4	7.2	7.4	7.5	7.5	7.4	7.4	7.5	6.9	7.0	7.0	7.0	6.9	6,5-8,5	7.2
ALCALINIDAD TOTAL	112	114	108	110	106	126	130	123	116	122	114	112	114	110	130	126	120	128	126	126	132	124		120
DUREZA TOTAL	346	350	276	280	340	340	372	398	386	398	394	376	364	356	340	328	336	326	320	310	334	326	500 MG/LT	345
DUREZA DE CALCIO	190	158	164	170	210	166	170	240	214	218	198	182	180	178	179	170	190	204	180	204	200	202		189
DUREZA DE MAGNESIO	156	192	112	110	130	174	202	158	172	180	196	194	184	178	161	158	146	122	140	106	134	126		156
CLORUROS	196	180	198	203	135	197	196	220	240	235	240	236	216	208	216	212	187	188	202	196	190	189	250 MG/LT	204
CLORO RESIDUAL	1.4	1.3	1.5	1.4	1.5	1.5	1.3	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0,2-1,5	1.5
SDT	645	606	660	689	735	729	811	872	779	625	788	730	728	710	660	690	654	936	619	601	582	596	1000 MG/LT	702
TEMPERATURA °C	17.4	17.4	21.5	20.9	22.7	23.0	23.1	23.7	23.7	22.7	19.7	20.6	16.3	16.7	17.1	16.7	14.2	13.1	14.3	16.0	18.2	18.7		19.0

AUTORIZÓ:

IQ. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO

Ve.Bo.

BIOLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA