



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA RIO BRAVO
 DICIEMBRE 2022**

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDIO
TURBIEDAD N.T.U.	11.0	12.1	10.0	9.8	10.3	10.6	11.2	10.8	11.7	13.5	16.8	17.1	17.3	18.5	19.3	18.9	20.8	21.3	19.0	18.2	17.7	16.8	15.1
P.H.	7.7	7.8	7.9	8.0	7.6	7.7	7.7	7.7	7.2	7.2	7.4	7.5	7.1	7.2	7.4	7.0	7.1	7.6	7.6	7.9	7.7	7.8	7.5
ALCALINIDAD TOTAL	130	124	150	152	148	140	148	150	152	156	154	150	152	146	154	148	144	160	150	150	150	140	148
DUREZA TOTAL	282	244	280	288	262	300	328	320	332	352	332	346	320	306	308	300	330	346	329	332	334	336	314
DUREZA DE CALCIO	154	143	172	186	160	176	182	180	190	196	186	189	180	166	177	188	192	212	170	230	182	196	181
DUREZA DE MAGNESIO	128	101	108	102	102	124	146	140	142	156	146	157	140	140	131	132	140	136	138	144	148	144	134
CLORUROS	167	158	147	178	185	190	176	192	198	190	180	182	172	170	168	176	163	164	155	150	156	149	171
SDT	516	516	512	519	569	591	623	644	600	550	604	601	625	610	600	567	536	821	530	526	501	569	579
TEMPERATURA °C	17.5	16.9	21.3	20.5	22.2	22.3	22.7	23.3	23.5	21.3	19.1	19.9	16.6	16.5	17.0	16.9	16.5	13.1	13.1	14.4	17.6	17.3	18.6

AUTORIZÓ:

Vo.Bo.

~~I.Q. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO~~

BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA