



PLANTA POTABILIZADORA PASTOR LOZANO

**ANALISIS FISICOQUÍMICOS
 AGUA CRUDA CANAL RODHE
 DICIEMBRE 2022**

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDIO
TURBIEDAD N.T.U.	32.8	27.4	39.8	41.4	33.9	27.4	37.4	46.3	45.1	40.3	50.4	47.9	36.8	38.6	36.3	32.6	39.7	36.4	39.8	40.1	39.7	42.6	38.8
P.H.	7.4	7.4	7.6	7.7	7.5	7.6	7.4	7.6	7.6	7.5	7.6	7.6	7.7	7.8	7.5	7.6	7.5	7.3	7.8	7.8	7.7	7.9	7.6
ALCALINIDAD TOTAL	102	108	122	126	120	118	106	102	110	126	130	118	116	120	128	130	118	124	119	110	114	116	117
DUREZA TOTAL	420	404	398	416	422	418	430	392	402	432	426	428	430	406	408	404	416	428	402	400	408	400	413
DUREZA DE CALCIO	232	200	240	250	230	246	251	228	236	245	236	230	234	220	214	218	222	232	186	206	214	219	227
DUREZA DE MAGNESIO	188	204	158	166	192	172	179	164	166	187	190	198	196	186	194	186	194	186	216	194	194	181	186
CLORUROS	280	274	284	296	288	296	288	290	287	292	309	280	268	270	282	280	264	250	254	245	246	230	275
SDT	927	941	1010	1015	1062	1045	1143	1115	1000	940	1005	965	900	902	875	870	848	820	788	800	804	828	937
TEMPERATURA °C	18.3	17.5	20.5	21.8	23.2	23.5	23.6	23.7	23.4	21.4	19.6	20.1	16.0	15.5	16.9	16.8	13.9	15.7	12.9	14.0	17.6	17.7	18.8

AUTORIZÓ:

Vo.Bo.

~~IQ. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO~~

BIOLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA