



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS  
AGUA CRUDA CANAL RODHE  
ENERO 2023

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	PROMEDIO
TURBIEDAD N.T.U.	40.8	50.9	68.3	70.1	69.8	79.9	89.0	77.8	52.0	51.7	43.5	48.6	62.3	62.7	75.3	73.7	82.4	70.5	60.8	58.7	88.7	74.6	66.0
P.H.	7.5	7.6	7.5	7.7	7.7	7.4	7.8	8.1	7.7	7.6	7.5	7.8	7.8	7.8	7.9	7.7	7.9	7.2	7.5	7.3	7.8	7.2	7.6
ALCALINIDAD TOTAL	114	100	100	102	116	128	120	120	112	114	120	118	124	124	114	116	120	124	120	130	126	128	118
DUREZA TOTAL	376	360	362	378	392	384	388	420	410	394	380	400	420	384	388	398	398	402	424	400	416	430	395
DUREZA DE CALCIO	212	200	204	212	220	216	210	226	212	210	216	238	220	228	206	218	210	230	232	210	220	215	217
DUREZA DE MAGNESIO	164	160	158	166	162	168	178	194	198	184	164	162	200	156	182	180	188	172	192	190	196	215	179
CLORUROS	236	232	234	232	234	235	228	234	236	298	302	358	376	352	360	364	350	370	320	244	281	240	287
SDT	679	671	673	663	644	668	672	680	696	720	882	898	890	811	785	774	762	757	764	700	748	705	738
TEMPERATURA °C	21.2	20.7	19.9	18.6	18.8	19.7	20.3	21.4	21.0	18.0	18.8	19.7	21.8	20.4	20.5	18.4	20.0	17.6	16.5	16.5	21.1	17.4	19.5

AUTORIZO:

IQ. TERESITA BARRÉNICE LÓPEZ MELGAR  
JEFA DE LABORATORIO

BIÓLOGO GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA