



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA POTABLE
 FEBRERO 2023

RESULTADOS EN MG/LT

FECHA:	1	2	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	4.8	4.6	4.7	4.9	5.0	5.0	5.0	4.8	5.0	5.0	4.9	4.7	5.0	4.8	4.7	5.0	4.9	5 NTU	4.9
P.H.	7.3	7.2	7.4	7.3	7.2	7.2	7.0	6.9	7.0	6.9	7.1	6.9	7.0	6.8	6.9	7.0	7.0	7.1	6.5-8.5	7.1
ALCALINIDAD TOTAL	128	140	132	126	132	118	124	120	116	110	118	120	126	118	116	112	120	126		122
DUREZA TOTAL	370	400	390	376	366	366	350	356	320	335	344	340	348	330	334	338	334	340	500 MG/LT	352
DUREZA DE CALCIO	200	216	192	172	166	178	170	174	150	158	164	168	170	164	166	168	166	178		173
DUREZA DE MAGNESIO	170	184	188	204	200	188	180	182	170	177	180	172	178	166	168	170	168	162		178
CLORUROS	210	214	194	202	198	190	182	180	176	180	192	188	186	184	170	176	174	180	250 MG/LT	188
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.5	1.5	1.4	1.5	1.5	1.5	0.2-1.5	1.5
SDT	650	692	600	615	575	611	624	610	616	702	770	780	720	796	698	656	690	640	1000 MG/LT	669
TEMPERATURA OC	15.0	14.1	20.6	20.8	19.4	19.1	17.5	20.1	21.5	21.7	18.5	20.5	21.8	23.2	23.8	24.8	23.8	23.3		20.5

AUTORIZO:

[Signature]
 IQ. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO

[Signature]
 BIOLOGO GUILLERMO NAVA LUIANO
 COORDINADOR DE CALIDAD DEL AGUA