



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA RIO BRAVO
FEBRERO 2023

RESULTADOS EN MG/LT

FECHA:	1	2	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	PROMEDIO
TURBIEDAD N.T.U.	21.5	18.3	14.8	17.5	18.2	18.1	19.8	21.3	22.8	17.9	18.3	23.6	23.7	26.1	29.0	28.0	32.7	29.1	22.3
P.H.	7.1	6.9	7.3	7.4	7.7	7.9	7.2	7.1	6.7	6.8	6.7	6.8	7.0	7.1	7.2	6.9	7.0	7.2	7.1
ALCALINIDAD TOTAL	134	142	152	152	142	136	136	128	130	136	140	148	138	136	128	130	134	130	137
DUREZA TOTAL	382	380	344	330	356	334	324	300	290	312	328	312	298	280	284	288	300	298	319
DUREZA DE CALCIO	182	212	184	198	170	184	180	170	164	174	182	180	174	160	162	168	171	166	177
DUREZA DE MAGNESIO	178	168	160	132	186	150	144	130	126	138	146	132	124	120	122	120	129	132	141
CLORUROS	184	194	166	164	176	164	150	155	152	146	150	140	132	130	128	119	125	120	150
SDT	625	668	554	550	540	557	536	573	598	604	660	648	644	686	588	600	598	600	602
TEMPERATURA °C	15.7	16.1	20.6	20.2	19.4	16.8	17.3	20.2	21.2	21.1	18.7	20.7	21.5	22.3	23.0	23.0	22.9	23.1	20.2

AUTORIZO:

I.Q. TERESITA BARENICE LOPEZ MELGAR
JEFA DE LABORATORIO

BIOLOGO DANIEL RAMIRO MAYA LUJANO
COORDINADOR DE CALIDAD DEL AGUA